


**LEGEND:**

- PROJECT BOUNDARY
- EX. PARCEL LINE
- EX. RIGHT-OF-WAY LINES
- EX. EASEMENT LINES
- EX. STREAM
- EX. TREELINE
- EX. WETLAND
- EX. OVERHEAD POWER
- EX. FENCE
- EX. GRAVEL ROAD
- EX. PAVED ROAD
- EX. STRUCTURE
- SOLAR ARRAY
- FENCE SETBACK LINE
- EASEMENT LINE
- INVERTER
- ACCESS ROAD
- SECURITY FENCE
- UNDERGROUND COLLECTOR
- SUBSTATION
- RESTRICTED AREA
- LAYDOWN YARD
- SITE ENTRANCE

SYSTEM SPECIFICATIONS	
ARRAY CAPACITY	494.22 MW DC
	370.80 MW AC (AT INVERTER)
	350.00 MW AC (AT POI)
DC/AC RATIO (AT INVERTER)	1.33
DC/AC RATIO (AT POI)	1.42
MODULE	LONGI LR5-72HBD
MODULE RATING	540W
MODULE QUANTITY	915,226
STRING QUANTITY (26 MOD/STRING)	35,201
INVERTER	SUNGROW CENTRAL INVERTER
INVERTER RATING	3.6 MVA
INVERTER QUANTITY	103
GCR	0.31

PREPARED FOR:  
**HARVEY SOLAR**  
 1105 Navasota St  
 Austin, TX 78702

REVISIONS:  
 # DATE COMMENT



**Harvey Solar**  
 Licking County, OH

Overall Site Plan

ISSUED FOR REVIEW  
 DATE: 08/05/2021  
 SHEET: C.200

8/5/2021 10:58 AM C:\GIS\Projects\154\15400001.dwg 154/2021 1:40 PM WWT/CS/ps